



**UNITED
TECHNOLOGIES
HAMILTON
STANDARD**

SVHSER 10638

NASA Contractor Report 181738

APPENDICES TO THE MODEL DESCRIPTION DOCUMENT

FOR

**A COMPUTER PROGRAM FOR THE
EMULATION/SIMULATION OF A SPACE STATION
ENVIRONMENTAL CONTROL AND LIFE SUPPORT SYSTEM**

BY

**HAMILTON STANDARD
DIVISION OF UNITED TECHNOLOGIES CORPORATION
WINDSOR LOCKS, CONNECTICUT**

PREPARED UNDER CONTRACT NO. NAS1-17397

FOR

**NATIONAL AERONAUTICS AND SPACE ADMINISTRATION
LANGLEY RESEARCH CENTER
HAMPTON, VIRGINIA**

September 1988

**(NASA-CR-181738) APPENDICES TO THE MODEL
DESCRIPTION DOCUMENT FOR A COMPUTER PROGRAM
FOR THE EMULATION/SIMULATION OF A SPACE
STATION ENVIRONMENTAL CONTROL AND LIFE
SUPPORT SYSTEM (Hamilton Standard Div.)**

N89-13895

**Unclas
G3/54 0183244**

ABSTRACT

A Model Description Document for the Emulation Simulation Computer Model was published previously. The model consisted of a detailed model (emulation) of a SAWD CO₂ removal subsystem which operated with much less detailed (simulation) models of a cabin, crew, and condensing and sensible heat exchangers. The purpose was to explore the utility of such an emulation/simulation combination in the design, development, and test of a piece of ARS hardware - SAWD.

Extensions to this original effort are presented in the manual. The first extension is an update of the model to reflect changes in the SAWD control logic which resulted from test. In addition, slight changes were also made to the SAWD model to permit restarting and to improve the iteration technique. The second extension is the development of simulation models for more pieces of air and water processing equipment. Models are presented for: EDC, Molecular Sieve, Bosch, Sabatier, a new condensing heat exchanger, SPE, SFWES, Catalytic Oxidizer, and multifiltration. The third extension is to create two system simulations using these models. The first system presented consists of one air and one water processing system. The second system consists of a potential Space Station air revitalization system complete with a habitat, laboratory, four modes, and two crews.

FOREWARD

This Model Description Document has been prepared by Hamilton Standard Division of United Technologies Corporation for the National Aeronautics and Space Administration's Langley Research Center in accordance with Contract NAS1-17397, "Development of an Emulation/Simulation Computer Model of a Space Station Environmental Control and Life Support System (ECLSS)". This manual describes the analytical models used in the three computer simulation programs developed under this contract.

Appreciation is expressed to the Technical Monitors, Messrs. John B. Hall, Jr. and Lawrence F. Rowell of the NASA Langley Research Center for their guidance and advice.

This manual was written by Dr. James L. Yanosy, Program Engineer, with assistance from Mr. Stephen A. Giangrande. The extensions to the program presented in this manual were performed under the direction of Mr. John M. Neel, Program Manager. Thanks is given to Mr. Joseph M. Homa for his efforts in the development of the Space Station Model.

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
	LIST OF FIGURES.....	iv
	LIST OF TABLES.....	v
1.0	INTRODUCTION.....	1
2.0	REFERENCES.....	2
 APPENDICES		
A.0	ESCM UPDATE.....	A-i
A.1	Introduction.....	A-1
A.2	SAWD Bed.....	A-1
A.3	SAWD Control Model.....	A-2
B.0	MODEL DESCRIPTION DOCUMENT FOR ECLSB MODEL.....	B-i
B.1	Introduction.....	B-1
B.2	Modelling of System.....	B-2
B.3	Modelling of Components.....	B-4
B.3.1	SPE Cells.....	B-5
B.3.2	Catalytic Oxidizer.....	B-10
B.3.3	Sabatier CO ₂ Reduction Subsystem.....	B-11
B.3.4	EDC CO ₂ Removal Subsystem.....	B-16
B.3.5	VCD Water Processing Subsystem.....	B-22
B.3.6	Filtration Models.....	B-23
B.3.7	Control.....	B-23
B.3.7.1	Nitrogen Addition Control.....	B-26
B.3.7.2	Oxygen Production Control.....	B-26
B.3.7.3	CO ₂ Partial Pressure Control.....	B-27
B.3.7.4	Cabin Temperature and Humidity Control.....	B-27
B.3.7.5	Water Tank Level Control.....	B-28
B.3.7.5.1	Urine and Wash Water Storage Tank.....	B-29
B.3.7.5.2	Clean Hygiene Water Storage Tank.....	B-29
B.3.7.5.3	Potable Water Storage Tank.....	B-31
B.3.7.5.4	Condensate Water Storage Tank.....	B-33
C.0	SPACE STATION MODEL.....	C-i
C.1	Introduction.....	C-1
C.2	Modelling of System.....	C-2
C.3	Modelling of Components.....	C-17
C.3.1	Molecular Sieve.....	C-18
C.3.2	Bosch.....	C-26
C.3.3	Static Feed Water Vapor Electrolysis (KOH).....	C-34
C.3.4	Plate Fin Condensing Heat Exchanger.....	C-37
C.3.5	Control	C-43

LIST OF FIGURES

<u>FIGURE NUMBER</u>	<u>TITLE</u>	<u>PAGE</u>
B-1	ECLS System B Schematic for G189 Type Computer Model.....	B-3
B-2	Catalytic Oxidizer Subsystem Schematic.....	B-12
B-3	EDC CO ₂ Removal Subsystem Schematic.....	B-17
C-1	Space Station Model Overview.....	C-3
C-2	Space Station Nodes.....	C-4
C-3	Overview of Habitat ARS.....	C-5
C-4	Overview of Laboratory ARS.....	C-6
C-5	Habitat Cooling Packages.....	C-7
C-6	Laboratory Cooling Packages.....	C-8
C-7	Habitat Oxygen Generators.....	C-9
C-8	Laboratory Oxygen Generators.....	C-10
C-9	Habitat CO ₂ Removal Units.....	C-11
C-10	Laboratory CO ₂ Removal Units.....	C-12
C-11	Habitat CO ₂ Reduction Units.....	C-13
C-12	Laboratory CO ₂ Reduction Units.....	C-14
C-13	Habitat Catalytic Oxidizers.....	C-15
C-14	Laboratory Catalytic Oxidizers.....	C-16
C-15	Molecular Sieve Subsystem Schematic.....	C-19
C-16	Bosch Process Subsystem Schematic.....	C-27

LIST OF TABLES

<u>TABLE</u>	<u>TITLE</u>	<u>PAGE</u>
B-1	SPE Cell Operating Efficiency.....	B-7
B-2	SPE Cell Voltage.....	B-8
B-3	Listing of GPOLY1 for ECLSB Model.....	B-24
B-4	Listing of GPOLY2 for ECLSB Model.....	B-25
B-5	Schedule for Dumping into Urine and Wash Water Storage Tank.....	B-30
B-6	Usage Schedule for Potable Water Tank.....	B-32

1.0 INTRODUCTION

The purpose of the original ESCM program was to demonstrate the utility of an emulation simulation computer program in the design, development and test of a piece of life support equipment. The piece of life support equipment selected for emulation was the SAWD CO₂ removal subsystem. A continuation of the effort called for an update of the computer model following testing of the SAWD unit. In addition, extensions to the contract called for the development of "lightweight" or low fidelity simulation models of contending life support equipment and the configuring of this equipment into two different systems.

This document provides three appendices to the original model description document[1]*. The appendices are:

- A. Emulation Simulation Computer Model Update
- B. Life Support System Model
- C. Space Station Model

The following errata were found in the original document:

- (1) Cover page: Report number should be SVHSER 9504.
- (2) Page 25, fifth line: Should be "HA = Total enthalpy of gas entering header, Btu"

*Numbers in brackets denote references listed in Section 2.0

2.0 REFERENCES

- (1) Yanosy, J., "Model Description Document for a Computer Program for the Emulation/Simulation of a Space Station Environmental Control and Life Support System (ESCM)", Hamilton Standard Report SVHSER 9504 for NASA Langley Research Center, NASA CR-181737, September 1988.
- (2) "G189A Generalized Environmental/Thermal Control and Life Support System Computer Program Manual", McDonnell Douglas Corporation MDAC-G2444; September, 1971.
- (3) Yanosy, J., "User's Manual for a Computer Program for the Simulation of a Space Station Environmental Control and Life Support System (ECLSB)", Hamilton Standard Report SVHSER 10630 for NASA Langley Research Center, September, 1986.

APPENDIX A
ESCM UPDATE

A.1 Introduction

The Space Station Environmental Control and Life Support System (ECLSS) Emulation/Simulation Computer Model (ESCM) has been updated to include: (1) the capability of restarting the SAWD CO₂ removal subsystem from a transient start-up, (2) placing clamps on the SAWD bed segment temperature when iterating the bed segment temperature during the energy balance of the bed segment, and (3) the addition of an energy balance control method where the amount of CO₂ on the bed is determined from the time for the CO₂ to begin coming off the bed as detected by the flow sensor. This latter change was made to reflect a change made to the control logic in the hardware. Each of these updates to ESCM as they pertain to the Model Description Document are presented in this Appendix.

A.2 SAWD Bed

The capability to start the SAWD subsystem without first running the steady state analysis was incorporated into the IR45 subroutine. The inlet and exit heater parameters, as well as SAWD bed segment parameters (i.e. temperature, pressure, molecular weight, and flow rates) were initialized in the IR45 subroutine; in a similar manner, they are initialized in the STEADY subroutine which is only called by IR45 in steady state. Therefore, the SAWD CO₂ removal subsystem can be started from a transient start-up as well as a steady state start-up.

Additional logic was also added to the IR45 BALANCE subroutine. Limits were placed on the SAWD bed segment temperature while iterating on the bed segment temperature for an energy balance of the segment. One of the limits employed was as follows: if the temperature entering the bed segment was greater than the SAWD bed temperature at the start of the time step, then the resulting bed segment temperature must increase.

A.3 SAWD Control Model

A new control method has been incorporated into the SAWD CO₂ removal subsystem model (IR45). This type of control uses an energy balance control scheme as opposed to the relative humidity method which was previously used. The energy balance method uses energy principles to determine the absorption time of the next cycle based on the bed's past desorb cycle. The total amount of energy for desorb can be calculated from the amount of steam added to the bed during desorb. The amount of CO₂ desorbed from the bed is known from techniques using the accumulator on the flow sensor; thus, the energy required to remove the CO₂ from the bed can be calculated. Also, the energy required to heat up the bed resins and canister before the desorption of CO₂ can be calculated. Therefore, from an energy balance, the amount of energy to heat the water which was on the bed at the start of the desorb can be calculated. Thus, the bed water loading at the start of the desorb can be determined. Knowing the amount of water on



the bed at the start of the desorb, the next absorption time can be determined. The following SAWD control logic has been incorporated in ESCM Subroutine GPOLY1 to determine the absorb time.

Control Constants (Set in subroutine GPOLY1):]

K0 = 1.11	K42 = 2.5	K47 = 7480.0	K51 = 1085
K1 = 0.045	K43 = 60.0	K48 = 60.87	K52 = 157.37
K16 = 115.01	K44 = 3.808	K49 = .00028205	K53 = 4.3167
K41 = 0.25	K46 = 0.6996	K50 = 0.0034246	K54 = 0.040259

Input:

CO2TIME	=	Time CO ₂ goes to cabin during desorb, minutes
DETIME	=	Time for desorption, minutes
INT1	=	Previous INT1 value.
NEWABTIME	=	Previous absorb cycle time, minutes.
ONTIME	=	Time steam generator is on during desorption, sec.
P	=	Accumulator pressure at end of desorption, sec.
PH2OPAST	=	Past value of bed loading for this bed. %.
TIN	=	Inlet temperature at end of desorbing bed's post absorb cycle, F
TOUT	=	Exit temperature at end of desorbing bed's past adsorbing cycle, F

All the following calculations are done at the end of desorption.

Calculate Bed CO₂ loading fraction which was at start of this desorb "FCO2".

```

Power      = ONTIME/(0.05769 * DETIME)
Power      = Clamp (Power, 1, 1040)
TSAT       = K54 * P**2 + K53 * P + K52
T3         = K16 * (TSAT - 212)/Power
T3         = Clamp (T3, 0.0, 17.5)
Ratio      = (CO2 Time - T3)/DETIME
FCO2       = K51*RATIO**2+K50*RATIO-K49
FCO2       = Clamp (FCO2, 0.0, 0.05)
  
```

Calculate Bed H₂O loading percent which was at start of this desorb "PCTH20".

```

WGTH20     = (K0 * ONTIME - K46 * (TSAT-TIN) - K47 * FCO2 - K48)/
              (TSAT-TOUT) - K1 * DETIME - K44
OCTH20     = 100.0 * WGTH20
IF((PCTH20 - OCTH20PAST).LT.-3.0) PCTH20 = PCTH20PAST-3.0
IF((PCTH20-PCTH20PAST).LT.-3.0) PCTH20 = PCTH20PAST-3.0
PCTH20     = Clamp (PCTH20, 10.0, 40.0)
  
```

Calculate new absorb cycle time, "NEWABTIME" in minutes.



```
INT1      = K41 * (PCTH20 - 25.0) + INT1
INT1      = Clamp (INT1, -35.0, 35.0)
NEWABTIME = K43 + K42 * (PCTH20 - 25.)
NEWABTIME = NEWABTIME + INT1
NEWABTIME = Clamp (NEWABTIME, 20., 90.)
```

The steam flow rate determines the desorption time. The control of the steam flow is not calculated based on the relative humidity in the cabin during the previous absorption cycle. The steam flow for the next desorption of the bed is based on the steam flow rate during the past desorb multiplied by the calculated steam generation power ratio.

$$MSN = MSO * PR$$

The steam generator power ratio is set equal to 1.0 for the first desorption of each SAWD bed. For all subsequent desorptions, the power ratio is calculated by squaring the actual time of the last desorption and dividing it by the product of the calculated time of the last desorption and the calculated time of the new desorption time.

$$PR = \frac{t_a * t_a}{t_{co} * t_{cn}}$$

where:

M_{SN} = New bed desorb steam flow, pph
 M_{SO} = Old bed desorb steam flow, pph
 P_R = Steam generator power ratio
 t_a = Actual time of last bed desorb, sec
 t_{co} = Calculated time of last bed desorb, sec
 t_{cn} = Calculated time of next bed desorb, sec

APPENDIX B**MODEL DESCRIPTION DOCUMENT FOR ECLSB MODEL**

B.1 Introduction

An extension to the original ESCM program is to develop lightweight simulation models of various life support equipment and to combine them into a system. The utility of using all lightweight models to enhance system design could then be explored. This differs from the original program which was to investigate the utility of a combined emulation and simulation model.

This manual provides the model description for one of the systems simulated. This system consists of one air revitalization group of equipment working in conjunction with one group of waste water processing equipment. The principal pieces of equipment are:

<u>Function</u>	<u>Subsystem</u>
CO ₂ Removal	Electrochemical Depolarized Concentrator
CO ₂ Reduction	Sabatier
O ₂ Generation	Static Feed Solid Polymer Electrolysis
Trace Gas Removal	Catalytic Oxidizer
Condensate Processing	Multifiltration
Urine Reclamation	Vapor Compression Distillation

B.2 Modelling of System

The life support system to be analyzed is shown in Figure B-1. The following discusses how this system represents real hardware.

The system shown in Figure B-1 consists of many components; however, some are the same. Therefore, models of only the following components are needed:

- | | |
|------------------------|----------------------------|
| (1) Crew | (8) EDC Cells |
| (2) Cabin | (9) Fan |
| (3) Fan | (10) Splitter |
| (4) Heat Exchanger | (11) Mixer |
| (5) SPE Cells | (12) All Purpose Component |
| (6) Catalytic Oxidizer | (13) VCD |
| (7) Sabatier | |

These components are arranged as required for use with G189A. Accordingly, particular items are arranged for modelling purposes but do not represent their actual physical location. First of all, the crew which consumes oxygen and produces carbon dioxide and water vapor is placed in series with other components before the cabin. This was done to keep the schematic simple and to minimize the number of components required. In actuality, the crew is in the cabin.




FIGURE B-1
ECLSS SYSTEM B SCHEMATIC FOR G189 TYPE COMPUTER MODEL

In the model in Figure B-1, it appears that the cabin has only four ports for gas flows - two entry and two exit. This is a restriction of G189A and again does not represent actuality. Air for the condensing heat exchanger, Sabatier cooling and the EDC are all drawn directly from the cabin. Since G189A has a limited number of ports, one port is used and then splitters are used to direct flow to each of the components. The end result is the same.

B.3 Modelling of Components

As discussed in Section B.2, only thirteen component analytical models need be available to analyze the life support system. The following sections will discuss these analytical models, the generation of performance constants, and any other parameters necessary to describe the analytical model. In many instances, the analytical model is already described in the G189A manual [2]. In those cases, the reader will be referred to the G189A manual for a description of the analytical model.

In addition to the thirteen components, the control of the cabin air conditions and the water tank levels are discussed.

Of the thirteen components, many were discussed previously in the ESCM Model Description Document [1]. The following are discussed here:

SPE Cells	Bacteria Filter
Catalytic Oxidizer	Charcoal Filter
Sabatier	Multifiltration
EDC Cells	Controls
VCD	

B.3.1 SPE Cells

The solid polymer electrolysis cells convert water to hydrogen and oxygen and give off heat to a heat exchanger with the coolant being air. The following constants and operating conditions are used:

A_c = unit cell area = 0.239 ft²

P_c = cell operating pressure = 200 psia

T_c = cell operating temperature = 155°F

N_c = number of cells = 20

The cell current density is determined from:

$$J_c = I/A_c$$

where I = cell current, amps

J_c = cell current density, amps/ft²



A cell efficiency is then determined by linear interpolation of the tables in Table B-1 for the cell pressure P_c , current density J_c , and cell temperature T_c . In addition, the voltage V_c across each cell is determined by linear interpolation of the tables in Table B-2 for the cell pressure P_c , current density J_c , and cell temperature T_c .

The total watts consumed by the cells becomes:

$$w_e = I V_c N_c$$

where V_c = voltage across each cell, volts

w_e = total electrical power of cells, watts

The amount of oxygen and hydrogen produced is given by:

$$m_{O_2} = 0.000659 I \frac{N_c}{100}$$

$$m_{H_2} = m_{O_2}/8$$

where: m_{O_2} = mass flow of oxygen produced, lbm/hr

m_{H_2} = mass flow of hydrogen produced, lbm/hr

The water consumed by electrolysis is given by:

$$m_{H_2O,E} = 1.125 m_{O_2}$$

TABLE B-1
SPE CELL OPERATING EFFICIENCY

Percent Efficiency at $T_c = 140^\circ\text{F}$

Cell Pressure (psia)

J_c (AMPS/FT ²)	<u>100</u>	<u>200</u>	<u>300</u>
50	91.1	84.7	82.7
100	95.0	90.0	86.4
150	96.8	93.5	90.3
200	97.5	95.1	92.6
250	98.0	96.0	94.0
300	98.3	96.6	94.9
350	98.6	97.2	95.7
400	98.7	97.6	96.2
450	98.9	97.8	96.7
500	99.1	98.1	97.0

Percent Efficiency at $T_c = 180^\circ\text{F}$
Cell Pressure (psia)

J_c (AMPS/FT ²)	<u>100</u>	<u>200</u>	<u>300</u>
50	87.8	82.4	79.0
100	93.0	86.7	82.9
150	95.4	90.7	86.3
200	96.6	92.9	89.1
250	97.2	94.2	91.2
300	97.7	95.1	92.6
350	98.0	95.8	93.7
400	98.3	96.4	94.5
450	98.4	96.7	95.1
500	98.0	97.1	95.6

TABLE B-2
SPE CELL VOLTAGE

Cell Voltage at $T_c = 140^\circ\text{F}$
Cell Pressure (psia)

J_c (AMPS/FT ²)	<u>100</u>	<u>200</u>	<u>300</u>
50	1.556	1.568	1.577
100	1.594	1.602	1.609
150	1.623	1.632	1.638
200	1.650	1.662	1.667
250	1.678	1.690	1.697
300	1.714	1.725	1.733
350	1.760	1.772	1.777
400	1.832	1.843	1.857

Cell Voltage at $T_c = 180^\circ\text{F}$
Cell Pressure (psia)

J_c (AMPS/FT ²)	<u>100</u>	<u>200</u>	<u>300</u>
50	1.503	1.514	1.522
100	1.537	1.548	1.553
150	1.562	1.573	1.581
200	1.587	1.599	1.606
250	1.614	1.624	1.632
300	1.639	1.651	1.657
350	1.670	1.682	1.689
400	1.701	1.722	1.728

where: $\dot{m}_{H_2O,E}$ = mass flow of water consumed by electrolysis,
lbm/hr

Water is also present as saturated vapor in the oxygen and hydrogen gas flows.

The amount is determined from the following relation:

$$Y_v = \frac{P_{sat}(T_c)}{P_c}$$

$$\dot{m}_{H_2O,O_2} = \frac{Y_v}{1-Y_v} \frac{\dot{m}_{O_2}}{MW_{O_2}} MW_{H_2O}$$

$$\dot{m}_{H_2O,H_2} = \frac{Y_v}{1-Y_v} \frac{\dot{m}_{H_2}}{MW_{H_2}} MW_{H_2O}$$

where: Y_v = mole fraction of water vapor

MW_{O_2} = molecular weight of oxygen, lbm/mole

MW_{H_2} = molecular weight of hydrogen, lbm/mole

P_{sat} = saturation pressure at given temp., psia

\dot{m}_{H_2O,O_2} = mass flow of water vapor in oxygen, lbm/hr

\dot{m}_{H_2O,H_2} = mass flow of water vapor in hydrogen, lbm/hr

Therefore, the total water consumed becomes:

$$\dot{m}_{H_2O,T} = \dot{m}_{H_2O,E} + \dot{m}_{H_2O,O_2} + \dot{m}_{H_2O,H_2}$$

The waste electrical power is given by:

$$w_w = w_e (1 - 1.48 \eta / V_c)$$

The heat given off to the ambient is given by:

$$Q = (w_w + 0.11 w_e + 27.3) 3.413$$

where Q = heat lost to ambient, Btu/hr.

All this heat is transferred to a heat exchanger which is cooled by ambient air.

B.3.2 Catalytic Oxidizer

The model of the catalytic oxidizer is a simple model which computes the temperature of the air stream exiting the unit. The composition of the air remains unchanged. The following constants are used:

w_{htr} = heater power = 28 watts

M_c = mass of high temperature bed catalyst = 2.0 lbm

T_c = operating temperature of high temp. catalyst = 600°F

s = fraction of air flow to high temp. catalyst = 0.1111

η_{HX} = heat exchanger effectiveness = 0.9

c_p = specific heat of air = 0.24 Btu/lbm-F

First the temperature leaving the high temperature bed is computed as:

$$T_h = T_c - \eta_{HX} (T_c - T_i)$$

where T_h = exit temp. from high temp. bed, °F

T_i = air inlet temp. to cat ox., °F

This high temperature air mixes with the air not going to the high temperature bed to give the resultant exit temperature.

$$T_e = \frac{s m_i T_h c_p + (1-s) m_i T_i c_p}{m_i c_p}$$

Figure B-2 shows a schematic of the catalytic oxidizer subsystem and the location of the above discussed temperatures and flows.

B.3.3 Sabatier CO₂ Reduction Subsystem

The Sabatier CO₂ reduction subsystem consists of the Sabatier reactor, a fan and a water separator as modeled for G189A.

A listing of the Sabatier subroutine SABHS is given in the ECLSB User's Manual [3]. The model is a simplified block box model which provides the gas composition exiting the reactor and the mixed temperature of the cooling air leaving the reactor and condensing heat exchanger.





FIGURE B-2
CATALYTIC OXIDIZER SUBSYSTEM SCHEMATIC

The Sabatier reaction is assumed to go to completion. First a test is made on the incoming gases to determine whether excess hydrogen or carbon dioxide exists. The reaction is:



$$\text{If } \frac{m_{\text{H}_2,i}}{2.016} < \frac{4 m_{\text{CO}_2,i}}{44.01}$$

then excessive carbon dioxide exists and all the hydrogen is consumed. For this case, the following relations hold:

$$m_{\text{CH}_4,e} = \frac{m_{\text{H}_2,i}}{4 M_{\text{H}_2}} M_{\text{CH}_4}$$

$$m_{\text{H}_2\text{O},e} = \frac{m_{\text{H}_2,i}}{4 M_{\text{H}_2}} 2 M_{\text{H}_2\text{O}} + m_{\text{H}_2\text{O},i}$$

$$m_{\text{H}_2,e} = 0.0$$

$$m_{\text{CO}_2,e} = m_{\text{CO}_2,i} - \frac{m_{\text{H}_2,i}}{4 M_{\text{H}_2}} M_{\text{CO}_2}$$

$$Q_{\text{sen}} = 8864. \frac{m_{\text{H}_2,i}}{4 M_{\text{H}_2}}$$

where: $m_{H_2,i}$ = mass flow of hydrogen entering reactor, lbm/hr
 $m_{H_2,e}$ = mass flow of hydrogen exiting reactor, lbm/hr
 $m_{CO_2,i}$ = mass flow of carbon dioxide entering reactor,
 lbm/hr
 $m_{CO_2,e}$ = mass flow of carbon dioxide exiting reactor,
 lbm/hr
 $m_{CH_4,e}$ = mass flow of methane exiting reactor, lbm/hr
 $m_{H_2O,e}$ = mass flow of water exiting reactor, lbm/hr
 $m_{H_2O,i}$ = mass flow of water entering reactor, lbm/hr
 MW = molecular weight, lbm/mole
 Q_{sens} = sensible heat produced by reaction, Btu/hr

On the other hand, if excess hydrogen exists, the following
 relations hold:

$$m_{CH_4,e} = \frac{m_{CO_2,i}}{MW_{CO_2}} MW_{CH_4}$$

$$m_{H_2O,e} = \frac{m_{CO_2,i}}{MW_{CO_2}} 2MW_{H_2O} + m_{H_2O,i}$$

$$m_{CO_2,e} = 0.0$$

$$m_{H_2,e} = m_{H_2,i} - \frac{m_{CO_2,i}}{MW_{CO_2}} 4MW_{H_2}$$



$$Q_{\text{sens}} = 8865. \frac{m_{\text{CO}_2, i}}{M_{\text{WCO}_2}} 4M_{\text{WH}_2}$$

The latent heat load to condense the water produced is

$$Q_{\text{LAT}} = 1050. m_{\text{H}_2\text{O}, e}$$

The temperature of the cooling air leaving the Sabatier is:

$$T_{\text{air}, e} = T_{\text{air}, i} + (Q_{\text{lat}} + Q_{\text{sens}}) / m_{\text{air}} c_p$$

where: m_{air} = mass flow of air, lbm/hr

The fan draws air around the reactor for cooling and through a condensing heat exchanger to condense the product water. The fan operational characteristics are:

$$\text{cfm} = 20.0$$

$$\text{power} = 34 \text{ watts}$$

The condensed water and product gases pass through a water separator which is modeled as an alternate component for use with G189A. All the water is separated from the product gases and 0.13 Btu/hr is added to the product gases in the form of heat.

B.3.4 EDC CO₂ Removal Subsystem

The EDC CO₂ removal subsystem removes carbon dioxide from the air stream through a fuel cell type process which requires hydrogen and produces electricity. Heat is removed through a water cooled heat exchanger. Again, simple black box models are used. See Figure B-3 for a schematic representation.

A listing of the EDC subroutine EDCHS is contained in Appendix A of the ECLSB User's Manual [3]. The following constants are used:

- J_d = design current density = 11 Amps/ft²
- R_{CO_2} = CO₂ transfer rate = 0.001736 lbm CO₂/amp-hr
- A_c = area per cell = ft²/cell
- T_c = cell operating temperature = 70°F
- P_c = cell operating pressure = 14.7 psia
- c_{PCO_2} = 0.211 Btu/lbm-F
- c_{PH_2} = 3.437 Btu/lbm-F
- c_{PO_2} = 0.221 Btu/lbm-F
- N_c = number of cells = 30

First, the carbon dioxide removal at design conditions is calculated using the following:

$$m_{CO_2,d} = R_{CO_2} J_d A_c N_c$$




FIGURE B-3
EDC CO₂ REMOVAL SUBSYSTEM

Then, a factor is computed for use in determining the actual CO₂ removed. This factor is given by:

$$J_{CO_2} = \left(\frac{J_A}{J_D} + 0.27 \right) \frac{1}{1.27}$$

The actual CO₂ removed becomes:

$$m_{CO_2,A} = m_{CO_2,d} K_{CO_2}$$

$$m_{CO_2,e} = m_{CO_2,i} - m_{CO_2,A}$$

where: J_A = actual current density, amps/ft²

$m_{CO_2,i}$ = mass flow of CO₂ into EDC, lbm/hr

$m_{CO_2,e}$ = mass flow of CO₂ exiting EDC in air stream, lbm/hr

The actual electrical characteristics required are:

$$I = 1.27 K_{CO_2} J_D A_c$$

$$V = \frac{J_A}{J_D} 0.5 N_c \quad \text{dividing line on separate half space}$$

$$w = I V$$



In the process, oxygen is consumed; the amount is given by the following relations:

$$P_{CO_2} = \frac{m_{CO_2,i}}{MW_{CO_2}} \cdot P_i \cdot \frac{760}{14.696}$$


$$\eta = 1.02 + \frac{0.19}{P_{CO_2}} - \frac{0.718}{P_{CO_2}^2}$$

$$m_{CO_2,c} = \frac{M_{CO_2,A}}{2} \cdot \frac{MW_{O_2}}{MW_{CO_2}}$$

$$m_{O_2,e} = m_{O_2,i} - m_{O_2,c}$$

where: P_i = inlet pressure of air to EDC, psia
 $m_{CO_2,i}$ = inlet mass flow of CO_2 into EDC, lbm/hr
 MW_{CO_2} = molecular weight of CO_2 = 44.01 lbm/mole
 P_{CO_2} = partial pressure of CO_2 in inlet air, mm Hg
 η = effectiveness of conversion
 MW_{O_2} = molecular weight of oxygen = 32 lbm/mole
 $m_{O_2,c}$ = mass flow of oxygen consumed, lbm/hr
 $m_{O_2,i}$ = mass flow of oxygen into EDC, lbm/hr
 $m_{O_2,e}$ = mass flow of oxygen exiting EDC air stream, lbm/hr

The factor of 2 in the preceding equation arises from the overall reaction taking place in the EDC cells:



Accordingly, the amount of hydrogen consumed is given by:

$$m_{\text{H}_2, \text{C}} = 2 \frac{m_{\text{O}_2, \text{C}}}{M_{\text{W}_{\text{O}_2}}} M_{\text{W}_{\text{H}_2}}$$

The amount of water produced is:

$$m_{\text{H}_2\text{O}, \text{P}} = \frac{m_{\text{H}_2, \text{C}}}{M_{\text{W}_{\text{H}_2}}} M_{\text{W}_{\text{H}_2\text{O}}}$$

Some of the water available leaves with the hydrogen and carbon dioxide gases. It is assumed that the vapor is saturated and that the pressure in the H₂-CO₂ exit port is 20 psia. The amount of water leaving with the H₂-CO₂ mixture is given by the following:

$$m_{\text{H}_2, \text{e}} = m_{\text{H}_2, \text{i}} - m_{\text{H}_2, \text{C}}$$

$$m_{\text{W}_{\text{mix}}} = \frac{m_{\text{H}_2, \text{e}} + m_{\text{CO}_2, \text{A}}}{\frac{m_{\text{H}_2, \text{e}}}{M_{\text{W}_{\text{H}_2}}} + \frac{m_{\text{CO}_2, \text{A}}}{M_{\text{W}_{\text{CO}_2}}}}$$

$$P_v = P_{\text{sat}}(T_c)$$

$$= \frac{M_{\text{H}_2\text{O}}}{M_{\text{mix}}} \frac{P_v}{P_T - P_v}$$

$$M_{\text{H}_2\text{O},\text{VE}} = \omega (m_{\text{CO}_2,\text{a}} + m_{\text{H}_2,\text{e}})$$

$$m_{\text{H}_2\text{O},\text{e}} = m_{\text{H}_2\text{O},\text{p}} + m_{\text{H}_2\text{O},\text{i}} + m_{\text{H}_2\text{O},\text{vi}} - m_{\text{H}_2\text{O},\text{ve}}$$

- where:
- $m_{\text{H}_2,\text{i}}$ = mass flow of hydrogen into EDC, lbm/hr
 - $m_{\text{H}_2,\text{e}}$ = mass flow of hydrogen exiting EDC, lbm/hr
 - M_{H_2} = molecular weight of hydrogen, lbm/moles
 - $M_{\text{H}_2\text{O}}$ = molecular weight of water, lbm/moles
 - M_{mix} = molecular weight of $\text{H}_2\text{-CO}_2$ mix exiting EDC, lbm/moles
 - P_v = vapor pressure of water in $\text{H}_2\text{-CO}_2$ stream, psia
 - P_{sat} = saturation pressure for given temp, psia
 - ω = humidity ratio
 - P_T = total pressure in $\text{H}_2\text{-CO}_2$ exit line, psia
 - $m_{\text{H}_2\text{O},\text{ve}}$ = vapor leaving with H_2 and CO_2 , lbm/hr
 - $m_{\text{H}_2\text{O},\text{i}}$ = mass flow of water into EDC from air stream, lbm/hr
 - $m_{\text{H}_2\text{O},\text{vi}}$ = mass flow of water into EDC with H_2 stream, lbm/hr

The total heat generated is given by:

$$Q_d = 65.7 + 766.8 m_{CO_2,d}$$

$$Q_{sens} = (1.06 K_{CO_2} - 0.06) Q_d$$

where: Q_d = design heat production, Btu/hr

Q_{sens} = actual heat production, Btu/hr

Of this heat, 25% is added to the air stream and 75% must be removed by the heat exchanger. Accordingly, the exit air temperature is given by:

$$T_e = T_i + \frac{0.25 Q_{sens}}{(m_{air,i} + m_{H_2O,vi}) c_p}$$

where: T_i = inlet air temperature, F

$m_{air,i}$ = inlet air flow, lbm/hr

c_p = specific heat of inlet air = 0.24 Btu/lbm-F

B.3.5 VCD Water Processing Subsystem

Vapor compression distillation process purifies water through a distillation type process. The model at present is simple and determines the amount of power consumed and the amounts of water and brine delivered. The following relations and constants are used:

$$m_{H2O,e} = 0.96 m_{H2O,i}$$

$$m_b = 0.04 m_{H2O,i}$$

$$w = \frac{m_{H2O,e}}{40.1} \quad 120$$

where: $m_{H2O,i}$ = mass flow of water into VCD = 2.30 lbm/hr for 3 man units or 2.73 lbm/hr for 6 man unit.

$m_{H2O,e}$ = mass flow of clean water exiting VCD, lbm/hr

m_b = mass flow of brine, lbm/hr

w = power required, watts

B.3.6 Filtration Models

Three filtration devices are modeled in ECLSB by the use of the Alternate Component subroutine. The three components are the bacteria filter, charcoal filter, and multifiltration. For each of these, the inlet flows and conditions pass through unchanged.

B.3.7 Control

A variety of items require control to operate the system effectively. CO₂ and O₂ levels in the cabin atmosphere need to be maintained, and water levels in the various tanks need to be regulated. This control logic is contained in subroutines GPOLY1 and GPOLY2, and listings of these are contained in Table B-3 and Table B-4 respectively.

TABLE B-3

LISTING OF GPOLY1 FOR ECLSB MODEL

```

SUBROUTINE GPOLY1
C
C
C   THIS SUBROUTINE PROVIDES THE CONTROL LOGIC FOR SYSTEM "B" ECLS
C   SIMULATION USING THE G189A COMPUTER PROGRAM.
C
C
C   TYPE STATEMENTS:
C
C   INTEGER ONCE
C   REAL      MR, INOM
C   LOGICAL  STEADY, CYCLIC, LTSIDE, OPEN, VCDON, MFTON
C
C   DIMENSION STATEMENTS:
C
C   DIMENSION V(1), K(1)
C   DIMENSION TURINE(8), THWASH(11), TSHOWR(2), TDRINK(8), TFOODP(5)
C
C   COMMON STATEMENTS:
C
C   COMMON /COMP/ DS(15), N, NA1, NB1, NC, NCAB, NCFL, NEXT, NEXV, NK,
1  NKEX, NKS, NKT, NLFL, NP, NPASS, NPF, NPFT(6), NQ, NS, NSF, NSFT(6),
2  NSTR(18), NSUBR, NV, NVT, Y(12)
C   COMMON /RARRAY/ IMAXR, R(0250)
C   COMMON /ECLST1/ KCHOUT, KPRNT, KPTINV(4), KWIT, KWIT1, KWIT2,
1  KWIT3, KWIT4, NUFF, KSTEDY
C   COMMON /KANDV/ K
C   COMMON /MISC/  DTIME, GRAV, KFLSYS, KOUTPT, KPDROP, KSYPAS, KTRANS,
1  LPSUM(5), MAXCI, MAXLP, MAXSLP, MAXSSI, NCOMPS, NEWDT, NLAST, NPASPD,
2  MINSSI, PGMIN, PLMIN, START, STEADY, TIME, TIMEMX, TMAX, TMIN, WTMAX
C   COMMON /CASE/ NCASE, NRSCS, NRECS
C   COMMON /PROPTY/ CPO, CP(99), CPCONL, CPCONV, CPCO2, CPDIL, CPOXY, CPTC,
1  GAMGAS, RHO0, RHO(99), VISCO, VISC(99), VISCAS, WIMO, WTM(99), WTMCON,
2  WTMIDIL, WTMTC, XKO, XK(99), XKGAS, XKLIQ, VISLIQ
C   COMMON /SOURCE/ A(19), B(19), CPA, CPB, IA1, IB1, NA, NB, NPFS, NPFST(6),
1  NSF5, NSFST(6), RHOA, RHOB, VISCA, VISCB, WTMA, WTMB, XKA, XKB
C   COMMON /VLOC/  IP, IS, IC, IQ, IV, IVT, IEX, INEXK
C   COMMON /LRC/  IDATE(2), ISCHM
C
C   DATA INITIALIZATION:
C
C   DATA TURINE / 0.1, 8.0, 6.0, 9.0, 12.0, 15.0, 20.0, 25.0/
C   DATA THWASH / 0.1, 8.0, 5.0, 6.0, 9.0, 10.0, 11.0, 12.0, 15.0, 20.0, 25.0/
C   DATA TSHOWR / 15.0, 25.0/
C   DATA TDRINK / 0.1, 8.0, 6.0, 9.0, 12.0, 15.0, 20.0, 25.0/
C   DATA TFOODP / 0.1, 5., 10., 14., 25.0/
C   DATA KU, KH, KS, KD, KF / 1, 1, 1, 1, 1/
C
C   EQUIVALENCE (V(1), K(1))

```

```

C      INITIALIZE AT START OF STEADY STATE SOLUTION.  DONE ONLY ONCE.
C
      IF(STEADY .AND. KSYPAS .LE. 1) THEN
        LTSIDE = .TRUE.
        TCABO = 0.0
        TDESO = 0.0
        IFREQ = VV(2,184)
        NMEN = KK(1,16)
        H2OADD = VV(2,128)
        CYCLIC = VV(2,185) .GT. 0.9
      END IF
C
      IF(N .EQ. 1) THEN
C
C      READ TABLE OF METABOLIC RATE VS MISSION TIME (24 HR CYCLE).
C
        TIMCYC = AMOD(TIME,86400.)
        MR = VALUE(1,TIMCYC,0.0)
        TCAB = VV(2,104)
        TCAB = 70.
        QL = MR-480.+(MR/1000.+ 10.)*(TCAB-60.0)
        QLMIN = 0.22*MR+2.6*(TCAB-60.0)
        QL = AMAX1(QL,QLMIN)
        QS = MR-QL
        R(66) = QS
        R(67) = QL
        R(82) = MR
      END IF
C
      IF(N .EQ. 2) THEN
        IF(STEADY .OR. MOD(KSYPAS,IFREQ) .EQ. 0) ISCHM = 1
        R(181) = DTIME
        R(182) = DTIME/60.
C
C      LIGHTSIDE - DARKSIDE?
C
        IF(CYCLIC) THEN
          TIMORB = AMOD(TIME,5400.)
          LTSIDE = TIMORB .LE. 2700.
        END IF
C
C      NITROGEN ADDITION RATE
C
        R(166) = 0.0
        WCN = 0.0
        PT = R(4)
        PO2 = R(94)
        IF(PT .GE. 14.819) GO TO 220
        IF (PT .GE. 14.818 .AND. PO2 .GE. 8.28) GO TO 220
        IF (PO2 .LT. 8.09) GO TO 220

```

```

C
C      REGULATOR LOGIC.
C
C      IF(OPEN) GO TO 210
C
C      N2 OPENING CURVES.
C
C      WCN  = VALUE(22,PT,0.0)
C      OPEN = .TRUE.
C      GO TO 220
C
C      N2 CLOSING CURVES.
C
C      210  WCN  = VALUE(28,PT,0.0)
C           IF(WCN .LE. 0.0) OPEN = .FALSE.
C
C      220  R(166) = WCN
C
C      OXYGEN AND H2O VAPOR ADDITION FROM SPE, LBM/HR
C
C      R(128) = H2OADD+VV(20,68)
C      R(165) = V(IV+2)
C
C      TRACE CONTAMINANTS ADDITION
C
C      END IF
C
C      IF(N .EQ. 8) THEN
C        IF(.NOT. STEADY .OR. KSYPAS .GE. 4) THEN
C          WSEC  = VV(7,1)
C          WPRI  = VV(5,1)
C          WTOT  = WSEC+WPRI
C          SR    = WSEC/WTOT
C          R(65) = SR
C        END IF
C      END IF
C
C      IF(N .EQ. 6) THEN
C        R(84) = 0.0
C        IF(VV(7,68) .GE. 560.) R(84) = 1.0
C      END IF
C
C      IF(N .EQ. 9) THEN
C        IF(.NOT. STEADY .OR. KSYPAS .GE. 4) THEN
C          WSEC  = VV(14,1)
C          WPRI  = VV(16,1)+VV(23,1)+VV(21,1)
C          WTOT  = WSEC+WPRI
C          SR    = WSEC/WTOT
C          R(65) = SR
C        END IF

```

```

      END IF
C
      IF(N .EQ. 11) THEN
        W8      = A(1)*R(72)/CPA
        W8      = AMAX1(W8,A(1))
        R(66)   = EXP(2.809-0.00169*B(1))*W8*(0.52+0.00026*B(1))
      END IF
C
      EXTRACT CONDENSATE WATER.
C
      IF(N .EQ. 13) THEN
        R(67)   = A(7)
        A(1)    = A(1)-A(7)
        A(7)    = 0.0
        CPA     = (A(5)*A(8)+A(6)*CPCONV)/A(1)
      END IF
C
      IF(N .EQ. 15) THEN
        IF(.NOT. STEADY .OR. KSYPAS .GE. 4) THEN
          WSEC   = VV(16,1)
          WPRI   = VV(28,1)+VV(21,1)
          WTOT   = WSEC+WPRI
          SR     = WSEC/WTOT
          R(65)  = SR
        END IF
      END IF
C
      IF(N .EQ. 16) THEN
        R(84)   = 1.0
        IF(.NOT. LTSIDE) R(84) = 0.0
      END IF
C
      IF(N .NE. 17) GO TO 1799
      IF(STEADY .AND. KSYPAS .LT. 4) GO TO 1799
      WSEC     = VV(21,1)
      WPRI     = VV(28,1)
      WTOT     = WSEC+WPRI
      SR       = WSEC/WTOT
      R(65)    = SR
1799  CONTINUE
C
      IF(N .NE. 18) GO TO 1899
      R(84)    = 1.0
      IF(.NOT. LTSIDE) R(84) = 0.0
1899  CONTINUE
C
      IF(N .NE. 19) GO TO 1999
      R(84)    = 1.0
      IF(.NOT. LTSIDE) R(84) = 0.0
1999  CONTINUE

```

```

C
20  IF(N .NE. 20) GO TO 2099
    INOM  - R(72)
    PO2   - VV(2,94)
    R(69) - INOM
    IF(PO2 .GE. 8.1) R(69) - 0.9*INOM
    IF(PO2 .LE. 2.9) R(69) - 1.1*INOM
    CALL SK(1,20,16)
    IF(LTSIDE) GO TO 2099
    R(69) - 0.0
    CALL SK(0,20,16)
2099 CONTINUE
C
21  IF(N .NE. 21) GO TO 2199
    R(65) - VV(20,65)
2199 CONTINUE
C
28  IF(N .NE. 28) GO TO 2899
    PCO2  - VV(2,100)
    R(68) - R(69)
    IF(PCO2 .GT. 8.0) R(68) - R(69)
    IF(PCO2 .LT. 2.0) R(68) - R(69)
    IF(LTSIDE) GO TO 2899
    R(68) - 0.0
2899 CONTINUE
C
24  IF(N .NE. 24) GO TO 2499
    R(65) - VV(28,65)
2499 CONTINUE
C
28  IF(N .NE. 28) GO TO 2899
C
C  EXTRACT CONDENSATE WATER.
C
    R(67) - A(7)
    A(1)  - A(1)-A(7)
    A(7)  - 0.0
    CPA   - (A(5)*A(8)+A(6)*CPCONV)/A(1)
2899 CONTINUE
C
82  IF(N .NE. 82) GO TO 8299
    CPA   - CPCONL
    RHOA  - RHO(1)
    CPB   - CPCONL
    RHOB  - RHO(1)
    WIMA  - WIM(1)
    WIMB  - WIM(1)
    VISCA - VISC(1)
    VISCB - VISC(1)
    XKA   - XK(1)

```

```

      XKB - XK(1)
8299  CONTINUE
C
85    IF(N .NE. 85) GO TO 8599
C
C      URINE DUMP TO STORAGE TANK, LBM/HR
C
      A(1) - 0.0
      IF (NMEN .EQ. 8) WDMP - 17./7.
      IF (NMEN .EQ. 6) WDMP - 26.28/7.
      TIMCYC - AMOD(TIME,86400.)
      IF(TIMCYC .LT. TURINE(7)*8600. .AND. KU .EQ. 8) KU - 1
      IF(TIMCYC .LT. TURINE(KU)*8600.) GO TO 8510
      KU - KU+1
      KU - MINO(KU,8)
      A(1) - WDMP/DTIME*8600.
C
C      WASTE HAND WASH WATER DUMP TO STORAGE TANK, LBM/HR
C
8510  WHWASH - 0.0
      IF(TIMCYC .LT. THWASH(10)*8600. .AND. KH .EQ. 11) KH - 1
      IF(TIMCYC .LT. THWASH(KH)*8600.) GO TO 8520
      KH - KH+1
      KH - MINO(KH,11)
      WHWASH - 11.5/10.
      A(1) - A(1)+WHWASH/DTIME*8600.
C
C      WASTE SHOWER WATER DUMP TO STORAGE TANK, LBM/HR
C
8520  WSHOWR - 0.0
      IF(TIMCYC .LT. TSHOWR(1)*8600. .AND. KS .EQ. 2) KS - 1
      IF(TIMCYC .LT. TSHOWR(KS)*8600.) GO TO 8530
      KS - KS+1
      KS - MINO(KS,2)
      WSHOWR - 22.5
      A(1) - A(1)+WSHOWR/DTIME*8600.
C
C      FLOW EXITING URINE WASH WATER STORAGE TANK, LBM/HR
C
8530  R(1) - 0.0
      IF(R(69) .LE. 80.) GO TO 8540
      VCDON - .TRUE.
      GO TO 8550
8540  IF(R(69) .GE. 27.) GO TO 8550
      VCDON - .FALSE.
8550  IF(.NOT. VCDON) GO TO 8599
      IF(NMEN .EQ. 8) R(1) - 2.80
      IF(NMEN .EQ. 6) R(1) - 2.78
8599  CONTINUE
C

```

```

41  IF(N .NE. 41) GO TO 4199
    H2OSPE = VV(20,67)
    R(1) = (WHWASH+WSHOWR)/DTIME*8600.+H2OSPE*WMFLT
4199 CONTINUE
C
42  IF(N .NE. 42) GO TO 4299
    WSEC = (H2OSPE+WMFLT)*DTIME/8600.
    WTOT = WSEC+WHWASH+WSHOWR
    IF(WTOT .LE. 0.0) GO TO 4299
    SR = WSEC/WTOT
    R(65) = SR
4299 CONTINUE
C
46  IF(N .NE. 46) GO TO 4699
    R(1) = 0.0
    WDRINK = 0.0
    TIMCYC = AMOD(TIME,86400.)
    IF(TIMCYC .LT. TDRINK(7)*8600. .AND. KD .EQ. 8) KD = 1
    IF(TIMCYC .LT. TDRINK(KD)*8600.) GO TO 4610
    IF (NMEN .EQ. 8) WDRINK = 19.56/7.
    IF (NMEN .EQ. 6) WDRINK = 81.82/7.
    KD = KD+1
    KD = MINO(KD,8)
    R(1) = WDRINK/DTIME*8600.
C
C  FOOD PREPARATION WATER DUMP TO STORAGE TANK, LBM/HR
C
4610 WFOODP = 0.0
    IF(TIMCYC .LT. TFOODP(4)*8600. .AND. KF .EQ. 5) KF = 1
    IF(TIMCYC .LT. TFOODP(KF)*8600.) GO TO 4699
    KF = KF+1
    KF = MINO(KF,5)
    IF(NMEN .EQ. 8) WFOODP = 4.74/4.
    IF(NMEN .EQ. 6) WFOODP = 9.48/4.
    R(1) = R(1)+WFOODP/DTIME*8600.
4699 CONTINUE
C
56  IF(N .NE. 56) GO TO 5699
    WSEC = WMFLT
    WTOT = WSEC+H2OSPE
    IF(WTOT .LE. 0.0) GO TO 5699
    SR = WSEC/WTOT
    R(65) = SR
5699 CONTINUE
C
58  IF(N .NE. 58) GO TO 5899
    WMFLT = 0.0
    R(1) = 0.0
    WPOT = VV(46,69)
    IF(WPOT .GE. 40.) GO TO 5810

```



```
MFTON = .TRUE.
GO TO 5820
5810 IF(WPOT .LE. 45.) GO TO 5820
MFTON = .FALSE.
5820 IF(.NOT. MFTON) GO TO 5899
IF(R(100)*DTIME/8600. .LE. R(69)) GO TO 5880
R(1) = 0.0
WMFLT = R(100)
GO TO 5899
5880 R(1) = R(100)
5899 CONTINUE
C
61 IF(N .NE. 61) GO TO 6199
IF(STEADY .AND. KSYPAS .LT. 4) GO TO 6199
TCAB = VV(2,104)
TDES = V(IV+28)
TTOL = 0.1
IF(ABS(TCAB-TDES) .LT. TTOL) GO TO 6199
A1 = 0.025
ITER = 1
CALL ESTIM(R(65),TCAB,TDES,R65OLD,TCABO,TDESO,A1,ITER,NSTR(1))
R(65) = AMAX1(R(65),0.0)
R(65) = AMIN1(R(65),0.9)
6199 CONTINUE
C
RETURN
END
```



TABLE B-4

LISTING OF GPOLY2 FOR ECLSB MODEL
SUBROUTINE GPOLY2

```
C
COMMON /COMP/ DS(15),N,NA1,NB1,NC,NCAB,NCFL,NEXT,NEXV,NK,
1 NKEX,NKS,NKT,NLFL,NP,NPASS,NPF,NPFT(6),NQ,NS,NSF,NSFT(6),
2 NSTR(18),NSUBR,NV,NVT,Y(12)
COMMON /RARRAY/ IMAXR,R(0250)
COMMON /ECLST1/ KCHOUT,KPRNT,KPTINV(4),KWIT,KWIT1,KWIT2,
1 KWIT3,KWIT4,NUFF,KSTEDY
COMMON /KANDV/ K
COMMON /MISC/ DTIME,GRAV,KFLSYS,KOUTPT,KPDROP,KSYPAS,KTRANS,
1 LPSUM(5),MAXCI,MAXLP,MAXSLP,MAXSSI,NCOMPS,NEWDT,NLAST,NPASPD,
2 MINSSI,PGMIN,PLMIN,START,STEADY,TIME,TIMEMX,TMAX,TMIN,WTMAX
COMMON /CASE/ NCASE,NRSCS,NRECS
COMMON /PROPTY/ CPO,CP(99),CPCONL,CPCONV,CPCO2,CPDIL,CPOXY,CPTC,
1 GANGAS,RHOO,RHO(99),VISCO,VISC(99),VISCAS,WTMO,WTM(99),WTMCON,
2 WTMDIL,WTMTC,XKO,XK(99),XKGAS,XKLIQ,VISLIQ
COMMON /SOURCE/ A(19),B(19),CPA,CPB,IA1,IB1,NA,NB,NPFS,NPFST(6),
1 NSFS,NSFST(6),RHOA,RHOB,VISCA,VISCB,WTMA,WTMB,XKA,XKB
COMMON /VLOC/ IP,IS,IC,IQ,IV,IVT,IEX,INEXK

C
DIMENSION V(1),K(1)

C
EQUIVALENCE (V(1),K(1))

C
LOGICAL STEADY

C
1 IF(N.NE.1) GO TO 199

C
C CALC NET FLOWS DUE TO CABIN PRI & SEC FLOW LOOPS
C
SBCO2 = 0.0
SBH2O = 0.0

C
C CALC NET H2O VAPOR CHANGE
C
125 XH2O = R(70) - SBH2O - VV(18,67) + VV(28,75) + VV(20,68)
CALL SV(XH2O,2,187)

C
C CALC NET O2 CHANGE
C
XO2 = -R(68) - VV(28,78) + VV(20,66)
CALL SV(XO2,2,175)

C
C CALC NET CO2 CHANGE
C
XC02 = R(69) - SBCO2 - VV(28,79)
CALL SV(XC02,2,177)

199 CONTINUE

C
2 IF (N .NE. 2) GO TO 299
```

```
      R(2)  - 70.  
      R(21) - 70.  
      R(89) - 0.42  
      R(98) - 46.  
      R(104) - 70.  
299  CONTINUE  
C  
18   IF(N.NE. 18) GO TO 1899  
      R(20) - R(67)  
      R(21) - R(2)  
      R(22) - 24.7  
      R(28) - 24.7  
1899 CONTINUE  
C  
28   IF(N.NE. 28) GO TO 2899  
      R(20) - R(67)  
      R(21) - R(2)  
      R(22) - 24.7  
      R(28) - 24.7  
      R(68) - VV(26,68)  
2899 CONTINUE  
C  
      RETURN  
      END
```

B.3.7.1 Nitrogen Addition Control

Nitrogen is added to maintain the total pressure in the cabin at a level of 14.813 psia. The same control as used and described in the ESCM Model Description Document [1] is used in the ECLSB model.

B.3.7.2 Oxygen Production Control

The oxygen level is controlled by adjusting the electrical current to the SPE cells according to the following:

$$P_{O_2} \geq 3.1 \text{ psia} \quad I = 0.9 I_{\text{NOM}}$$

$$P_{O_2} \leq 2.9 \text{ psia} \quad I = 1.1 I_{\text{NOM}}$$

where: P_{O_2} = partial pressure of O_2 in cabin, psia

I = current to SPE cells, amps

I_{NOM} = nominal current to cells = 22 amps

This nominal electrical current corresponds to a nominal oxygen consumption rate for three men at 0.255 lbm/hr.



B.3.7.3 CO₂ Partial Pressure Control

At present, the EDC production current is not adjusted in response to changes in the CO₂ partial pressure in the cabin. The current density is maintained at a constant 11.0 amps per square foot. The user may change this control logic by making desired changes in the GPOLY1 subroutine.

B.3.7.4 Cabin Temperature and Humidity Control

Control of cabin temperature and humidity is accomplished by regulating the fraction of air flow from the cabin which passes through the condensing heat exchanger. The more air through the heat exchanger, the cooler the cabin should become. The technique to regulate the fraction to the heat exchanger is described by the following relations:

$$\text{For } |T_1 - T_s| < 0.1^\circ\text{F}$$

the fraction remains unchanged. Otherwise;

$$f = f_1 + 0.025 \frac{f_2 - f_1}{T_1 - T_2} \quad T_1 - T_s$$

and f is clamped between 0 and 0.9.

Where: f = new flow fraction bypassing heat exchanger

f_1 = last flow fraction

f_2 = flow fraction prior to f_1

T_1 = last cabin temperature, °F

T_2 = cabin temperature prior to T_1 , °F

T_s = set point cabin temperature, °F

This is tantamount to a straight integral control technique with a varying integration gain constant.

The effects of this control on cabin temperature and humidity are negated, however, by the logic in GPOLY2. GPOLY2 simply sets the cabin temperature to 70°F, the humidity to 42%, and the dew point to 46°F. This was done to give reasonable temperatures until a new control law can be developed.

B.3.7.5 Water Tank Level Control

Four water tanks are used for storage of clean and waste water; they are:

- (1) Urine and Wash Water Storage Tank
- (2) Clean Hygiene Water Storage Tank
- (3) Potable Water Storage Tank
- (4) Condensate Water Storage Tank

For each of these tanks, the calculations for the entering and exiting water flows are presented in the following paragraphs.

B.3.7.5.1 Urine and Wash Water Storage Tank

The Urine and Wash Water Storage Tank receives water from crew urination, hand washing, and showering. The amount of water for each of these activities is considered to be dumped into the tank over a period of one time step which is currently 120 seconds or two minutes. Table B-5 gives the amount and time of day at which water is dumped into the tank for each of these activities. This table, of course, may be altered by the user by appropriate changes to the logic in GPOLY1.

Flow will exit the tank only if the VCD unit is on. The VCD unit turns on whenever the tank level is greater than 30 percent full and turns off if the tank level falls below 27 percent full. When the VCD is on, it draws water at 2.3 lbm/hr for a three man unit and 2.73 lbm/hr for a six man unit.

B.3.7.5.2 Clean Hygiene Water Storage Tank

The Clean Hygiene Water Storage Tank receives water from the VCD unit at the rate processed by the VCD. Water is used from this tank for handwashing and showers and to supply the needs of the SPE and Multifiltration units. Accordingly, water for handwashing and

TABLE B-5
SCHEDULE FOR DUMPING INTO URINE AND
WASH WATER STORAGE TANK

Water Dumped (lbm)				
<u>Time of Day</u>	<u>3 Men</u>	Urine <u>6 Men</u>	<u>Hand-wash</u>	<u>Shower</u>
8:06 AM	2.429	3.754	1.15	
9:00				
10:00				
11:00	2.429	3.754	1.15	
12:00				
1:00 PM			1.15	
2:00	2.429	3.754	1.15	
3:00				
4:00				
5:00	2.429	3.754	1.15	
6:00			1.15	
7:00			1.15	
8:00	2.429	3.754	1.15	
9:00				
10:00				
11:00	2.429	3.754	1.15	22.5
12:00				
1:00 AM				
2:00				
3:00				
4:00	2.429	3.754	1.15	
5:00				
6:00				
7:00				
8:00				
	<hr/>	<hr/>	<hr/>	<hr/>
	17.00	26.28	11.5	22.5

showers is drawn from the tank according to the schedule in Table B-5. Again, all the water for a given time in the table is presumed to be drawn over one time step, i.e., two minutes.

The water required by the SPE unit is given in Section B.3.1 by the relation for $m_{H_2O,t}$. The water required for the multifiltration unit is 2.55 lbm/hr. However, water is drawn from the Hygiene Tank only if the condensate tank is unable to supply the multifiltration needs.

B.3.7.5.3 Potable Water Storage Tank

The potable water storage tank receives water from the multifiltration unit. The multifiltration unit is supplied by a water pump which draws water from the condensate storage tank or the clean hygiene water storage tank if the condensate tank has insufficient water. The pump draws water at 2.55 lbm/hr. The multifiltration unit pump turns on when the tank level falls below 90% full and turns off if the level rises above 45%.

Water is drawn from the tank for drinking and food preparation. Again, the amount of water drawn for each of these activities is considered to be drawn from the tank over a period of one time step which is currently two minutes. Table B-6 gives the amount and time of day for each of these activities.

TABLE B-6
 USAGE SCHEDULE FOR POTABLE WATER TANK

Time of Day	Water Used (lbm)		Food Preparation	
	Drinking <u>3 Men</u>	<u>6 Men</u>	<u>3 Men</u>	<u>6 Men</u>
8:06 AM	2.794	4.474	1.185	2.370
9:00				
10:00				
11:00	2.794	4.474		
12:00				
1:00 PM			1.185	2.370
2:00	2.794	4.474		
3:00				
4:00				
5:00	2.794	4.474		
6:00			1.185	2.370
7:00				
8:00	2.794	4.474		
9:00				
10:00			1.185	2.370
11:00	2.794	4.474		
12:00				
1:00 AM				
2:00				
3:00				
4:00	2.794	4.474		
5:00				
6:00				
7:00				
8:00				
	<hr/>	<hr/>	<hr/>	<hr/>
	19.560	31.320	4.740	9.480

B.3.7.5.4 Condensate Water Storage Tank

The condensate water storage tank receives condensate water from the condensing heat exchanger and the Sabatier reactor water separator. Water is drawn from the condensate tank as required by the multifiltration unit to supply the potable water needs. When water is drawn, it is drawn at 2.55 lbm/hr.

APPENDIX C

SPACE STATION MODEL

C.1 Introduction

This manual provides the model description document for a Space Station model which includes a habitat, laboratory, and four nodes. Only the air revitalization equipment is modelled; waste water management tanks and processing equipment are not included in the model. The principal pieces of equipment are:

<u>Function</u>	<u>Subsystem Option Available</u>
CO ₂ Removal	EDC, Molecular Sieve
CO ₂ Reduction	Bosch, Sabatier
O ₂ Generation	SPE, KOH
Trace Gas Removal	Catalytic Oxidizer
Condensate Processing	Plate-fin shuttle type heat exchanger

Options are also available for hydrogen or CO₂ bussing.

C.2 Modelling of System

Figures C-1 through C-14 present the schematics of the system as modeled using G189A. The following discusses how this system represents real hardware. Further descriptions of the system can be found in the User's Manual [4].

In these schematics, extra lines, mixers, and splitters are inserted to provide the user with flexibility to select various options without having to rewrite the programs. These lines do not represent actual plumbing arrangements of a Space Station. For example, a duct does not exit the habitat then tee to two modes as shown in Figure C-1. In actuality, a node is adjacent to the habitat and a fan draws air directly from the habitat into the node. Therefore, these are functional schematics and do not represent actual plumbing.




FIGURE C-1
SPACE STATION MODEL OVERVIEW




FIGURE C-2
SPACE STATION NODES




FIGURE C-3
OVERVIEW OF HABITAT ARS




FIGURE C-4
OVERVIEW OF LABORATORY ARS




FIGURE C-5
HABITAT COOLING PACKAGES




FIGURE C-6
LABORATORY COOLING PACKAGES




FIGURE C-7
HABITAT OXYGEN GENERATORS




FIGURE C-8
LABORATORY OXYGEN GENERATORS




FIGURE C-9
HABITAT CO₂ REMOVAL UNITS




FIGURE C-10
LABORATORY CO₂ REMOVAL UNITS




FIGURE C-11
HABITAT CO₂ REDUCTION UNITS




FIGURE C-12
LABORATORY CO₂ REDUCTION UNITS




FIGURE C-13
HABITAT CATALYTIC OXYDIZERS




FIGURE C-14
LABORATORY CATALYTIC OXIDIZERS

C.3 Modelling of Components

The following sections discuss the analytical models of the components available in this Space Station model. Some of these have been described elsewhere. The following lists the subsystems and where they have been discussed.

<u>Subsystem</u>	<u>Reference</u>
SPE	Appendix B
Catalytic Oxidizer	Appendix B
Sabatier	Appendix B
EDC	Appendix B

The following subsystems are discussed below:

Molecular Sieve
Bosch
KOH
Plate Fin Heat Exchanger
Control Logic



C.3.1 Molecular Sieve

Molecular Sieve removes carbon dioxide from incoming air. Some constants are:

t_h	= half cycle time = 60 minutes
P_{min}	= min. pressure of desorbing mole sieve bed = 1.0 psia
T_{MMS}	= max. temperature of desorbing mole sieve bed = 360°F
T_{MSG}	= max. temperature of desorbing silica gel bed = 180°F
cfm	= fan cfm = 23.25
ΔP_{fan}	= 11 in H ₂ O
	= fan efficiency = 0.35
	= CO ₂ removal efficiency = 0.65
ΔH_{SG}	= enthalpy change for adsorbing silica gel bed = 1400 Btu/lb H ₂ O
ΔH_{MS}	= enthalpy change for adsorbing mol sieve bed = 1800 Btu/lb CO ₂
CFM_c	= compressor cfm = 1.05

In order to understand the analytical description, the schematic of the molecular sieve subsystem shown in Figure C-15 should be reviewed.




FIGURE C-15
MOLECULAR SIEVE SUBSYSTEM SCHEMATIC

First, the temperature leaving the fan is computed by the following:

$$T_2 = T_1 + \frac{Q_{FAN}}{m_a c_p}$$

where: T_2 = temperatures leaving fan, F

T_1 = temperature entering fan, F

Q_{FAN} = fan power, Btu/lb

$$Q_{FAN} = \frac{\text{cfm } \Delta P_{FAN}}{8.5 \eta} \quad 3.413$$

m_a = air inlet mass flow to fan, lbm/hr

c_p = specific heat of air, Btu/lbm-F

Next, the temperature of the process air leaving the adsorbing silica gel bed is calculated from the following:

$$T_{3MAX} = T_2 + \frac{\omega \Delta h_{sg}}{c_p}$$

$$m_{sg} = \frac{T_{3MAX} - T_3}{600 - t_h}$$

$$T_3 = T_3 + m_{sg} \Delta t$$

where: ω = absolute humidity of air entering molecular sieve

T_{3max} = maximum temperature of air leaving the adsorbing silica gel bed, F

m_{sg} = change of air temperature leaving silica gel bed with time, F/sec

Δt = simulation time step, sec

t_h = time into half cycle, sec

After 10 minutes into the half cycle, the temperature of the air leaving the silica gel bed is limited to T_{3max} .

The water removed by the silica gel bed is:

$$M_{H2O} = M_{H2O} + (M_{H2O,in}) \Delta t$$

where: M_{H2O} = mass of water removed by silica gel bed during half cycle, lbm

$M_{H2O,in}$ = flow of vapor and entrained liquid entering system, lbm/hr

Thus the assumption is that all the moisture entering the system is adsorbed onto the silica gel bed. Now, the temperature and mass flow of cool dry air leaving the heat exchanger is:

$$T_4 = T_{cool} + 5^{\circ}F$$

where: T_{cool} = temperature of coolant water entering HX, F

T_4 = temperature of air leaving HX, F

The heat transferred by the heat exchanger to the water is:

$$Q_{HX} = m_d c_p (T_3 - T_4)$$

where: m_d = mass flow of dry air which entered molecular sieve subsystem, lbm/hr

The air flows next to the CO₂ adsorbing molecular sieve bed. The temperature of the air leaving that bed is given by the following calculations:

$$m_{CO_2,a} = m_{CO_2,i} \epsilon_{CO_2}$$

$$M_{CO_2,a} = M_{CO_2,a} + m_{CO_2,A} \Delta t$$

$$P_{CO_2,e} = P_{CO_2,i} (1 - \epsilon_{CO_2})$$

$$m_{CO_2,e} = m_{CO_2,i} (1 - \epsilon_{CO_2})$$

$$T_{5,MIN} = T_4 + \frac{M_{CO_2,a} \Delta h_{ms}}{m_d c_p}$$

$$m_{ms} = \frac{T_{5,min} - T_5}{1800 - t_h}$$

$$T_5 = T_5 + m_{ms} \Delta t$$

where: $m_{CO_2,i}$ = inlet CO_2 mass flow into molecular sieve bed, pph
 ϵ_{CO_2} = CO_2 removal efficiency of molecular sieve bed
 $m_{CO_2,a}$ = rate of CO_2 adsorption, lbm/hr
 $M_{CO_2,a}$ = total mass of CO_2 present on bed, lbm
 $P_{CO_2,i}$ = partial pressure of CO_2 in inlet air, psia
 $P_{CO_2,e}$ = partial pressure of CO_2 in molecular sieve exit
 bed, psia
 $m_{CO_2,e}$ = exit CO_2 mass flow out of molecular sieve bed, pph
 $T_{5,min}$ = minimum temp. exiting molecular sieve bed, F

After 1,800 seconds into the half cycle, the exit temperature cannot be less than $T_{5,min}$.

The process air then flows to the desorbing silica gel bed. The temperature of the bed rises for the first 17 minutes, peaks, then falls for 17 minutes until the temperature reaches a minimum $T_{5,min}$. The equations are:

For the first 17 minutes:

$$M_{sgd} = \frac{T_{MSG} - T_6}{1020 - t_h}$$

$$T_6 = T_6 + M_{sgd} \Delta t$$

where: t_6 = temperature leaving, desorbing silica gel bed, F

M_{sgd} = temperature change with time of airleaving desorbing
 silica gel bed, F/sec

This temperature T_G cannot exceed T_{msg} .

For the next 17 minutes:

$$M_{sgd} = \frac{T_{5,min} - T_6}{2040 - t_h}$$

$$T_6 = T_6 + M_{sgd} \Delta t$$

For these 17 minutes, the air temperature is limited to a minimum of $T_{5,min}$. From 34 minutes into the half cycle to the end of the half cycle, the temperature exiting the desorbing silica gel bed is set to $T_{5,min}$.

The properties of the air leaving this silica gel bed are:

$$P_{H2O} = P_{SAT}(T_6)$$

$$m_{H2O} = \frac{M_{W_{H2O}}}{M_{W_d}} \frac{P_{H2O}}{P_T - P_{H2O}} m_d$$

$$M_{sgd} = M_{sgd} + m_{HSO} \Delta t$$

where: P_{HSO} = partial pressure of water vapor in air, psia

m_{H2O} = mass flow of water leaving silica gel bed, pph

M_{sgd} = mass of water desorbed from bed this half cycle, lbm

Of course, the mass desorbed is limited to the mass adsorbed from the previous cycle.

The electrical power to the desorbing silica gel bed is given by:

$$\begin{aligned} \text{For } t_h < 240 \text{ seconds} \quad W_{htr} &= 0 \text{ watts} \\ t_h \geq 240 \text{ seconds} \quad W_{htr} &= 657 \text{ watts} \end{aligned}$$

The average heat given up by the desorbing silica gel bed to the cabin is:

$$Q_{sg} = \frac{46}{290} (T_{msg} - T_{cab})$$

where: T_{cab} = cabin air temperature, F

The final calculation is that for the mass of CO_2 desorbed from the molecular sieve bed. The following equations are used for $t_h > 480$ seconds.

$$\gamma_7 = \frac{R (T_4 + 460)}{144 P_{min} MW_{CO_2}}$$

$$M_{CO_2,d} = \left[1.01 + 0.01 \left(\frac{P_8}{P_{min}} \right)^{0.769} \right] \frac{cfm_c}{\gamma_7}$$

where: R = Universal gas constant = 1545 ft-lbf/mole R

MW_{CO_2} = Molecular weight of CO_2 = 44 lbm/mole

P_{min} = Minimum pressure of desorbing molecular sieve, psia

P_8 = Accumulator pressure, psia

cfm_c = Compressor cfm_c

$m_{CO_2,d}$ = Mass flow of CO_2 desorbed, lbm/hr

For $t_h < 480$ seconds, $m_{CO_2,d} = 0$.


The total carbon dioxide desorbed during the present half cycle is given by:

$$M_{CO_2,d} = M_{CO_2,d} + m_{CO_2,d} \Delta t$$

Of course, the total amount desorbed is limited to the amount of CO_2 that was originally present on the bed.

C.3.2 Bosch

The Bosch is a process that reduces carbon dioxide and hydrogen to carbon and water while giving off heat. The model used here is based on the one described in the G189A Manual [2]. A functional schematic of the process is shown in Figure C-16. The chemical reaction is described by:



A listing of the program is provided in the User's Manual Appendices [4].

First the molecular weight of bone dry condenser exit gas and the inlet molar flows of H_2 and CO_2 are computed.




FIGURE C-16
BOSCH PROCESS SUBSYSTEM SCHEMATIC

$$n_{H_2,i} = m_{H_2,i}/2.016$$

$$n_{CO_2,i} = m_{CO_2,i}/44.011$$

$$MW_{BDG} = 16.043 Y_{CH_4} + 44.011 Y_{CO_2} + 2.016 Y_{H_2} + 28.011 Y_{CO}$$

where: $m_{H_2,i}$ = Mass flow of H_2 entering Bosch system, pph
 $n_{H_2,i}$ = molar flow of H_2 entering Bosch system, moles/hr
 $m_{CO_2,i}$ = mass flow of CO_2 entering Bosch system, pph
 $n_{CO_2,i}$ = molar flow of CO_2 entering Bosch system, pph
 Y_{CH_4} = mole fraction of methane in dry cond. exit gas = .235
 Y_{CO_2} = mole fraction of CO_2 in dry cond. exit gas = .163
 Y_{H_2} = mole fraction of H_2 in dry cond. exit gas = .327
 Y_{CO} = mole fraction of CO in dry cond. exit gas = .275
 MW_{BDG} = molecular weight of bone dry cond. exit gas

The amount of carbon processed and water produced for a quasi-equilibrium assumption is given by the following which is based on the reaction formula:

If CO_2 limiting:

$$m_{C,p} = m_{CO_2,i} * MW_C$$

$$m_{H_2O,p} = 2 m_{CO_2,i} * MW_{H_2O} + m_{H_2O,i}$$

If H_2 limiting:

$$m_{C,p} = m_{H_2,i} MW_C/2$$

$$m_{H_2O,p} = m_{H_2,i} MW_{H_2O} + m_{H_2O,i}$$

where: MW_C = molecular weight of carbon = 12.011 lbm/mole

MW_{H_2O} = molecular weight of water = 18.016 lbm/mole

$m_{H_2O,i}$ = mass flow of vapor and entrained liquid entering
 Bosch system, lbm/hr

$m_{C,p}$ = mass rate of carbon production, lbm/hr

$m_{H_2O,p}$ = mass rate of water production, lbm/hr

Therefore, flow out of condenser is:

$$m_3 = m_r - m_{C,p} - m_{H_2O,p}$$

where: m_r = recycle flow rate on more specifically the mass
 flow at the compressor = 6.80 lbm/hr

The temperature at the condenser exit is iterated upon. Its initial value is assumed to be 20°F hotter than the inlet coolant temperature:

$$T_3 = T_{cool} + 20$$

The iteration begins with the calculation of the flow rate of bone dry condenser exit gas

$$m_{BDG} = \frac{m_3}{1 + \frac{M_{H_2O}}{M_{BDG}} \frac{P_{H_2O}}{P_{COND} - P_{H_2O}}} \quad P_{H_2O} = P_{sat}(T_3)$$

where: P_{H_2O} = partial pressure of vapor leaving condenser, psia

P_{COND} = total pressure of recycle gas in condenser =
16.9 psia

m_{BDG} = mass flow of bone dry gas leaving condenser, pph

Accordingly, the flows out of the condenser and compressor are:

$$n_{BDG} = \frac{m_{BDG}}{M_{BDG}}$$

$$m_{H_2O, 3} = \frac{P_{H_2O}}{P_{cond}} n_{BDG} M_{H_2O}$$

$$m_{H_2O, 4} = m_{H_2O, 3} + m_{H_2O, 2}$$

$$m_{H_2, 3} = n_{BDG} Y_{H_2} M_{H_2}$$

$$m_{H_2, 4} = m_{H_2, 3} + m_{H_2, 2}$$

$$m_{CO_2, 3} = m_{BDG} Y_{CO_2}$$

$$m_{CO_2, 4} = m_{CO_2, 3} + m_{CO_2, 2}$$

$$m_{CH_4, 3} = n_{BDG} Y_{CH_4} M_{CH_4}$$

$$m_{CH_4, 4} = m_{CH_4, 3}$$

$$m_{CO, 3} = n_{BDG} Y_{CO} M_{CO}$$

$$m_{CO, 4} = m_{CO, 3}$$

The properties of the flow exiting the compressor are:

$$C_{p4} = (3.42 m_{H2,4} + 0.21 m_{CO2,4} + 0.55 m_{CH4,4} + 0.25 m_{CO,4} + 0.49 m_{H2O,4} + 0.22 m_{O2} + 0.299 m_{N2}) / m_r$$

$$MW_4 = m_r / (m_{H2,4}/2.016 + m_{CO2,4}/44.011 + m_{CH4,4}/16.043 + m_{CO,4}/28.011 + m_{H2O,4}/18.06 + m_{O2}/32 + m_{N2}/28.088)$$

$$\gamma_4 = \frac{C_{p4}}{C_{p4} - \frac{1,987}{MW_4}}$$

where: C_{p4} = Specific heat of gas at compressor exit, BTU/lbm-F
 MW_4 = Molecular weight of gas at compressor exit,
 lbm/mole

γ_4 = Ratio of constant pressure to constant volume
 specific heats

m_{O2} = Mass flow of oxygen in recycle gas = 0.0 lbm/hr

m_{N2} = Mass flow of nitrogen in recycle gas = 0.0 lbm/hr



The mixed temperature of inlet gases and the recycle gases exiting condenser is given by:

$$T_6 = [(m_{BDG} C_{PBDG} + 0.49 m_{H_2O,3} T_3 + 0.21 m_{CO_2,i} + 3.42 m_{H_2,i} + 0.49 m_{H_2O,iv} + 1.0 m_{H_2O,ie}] / (m_r C_{p4})$$

$$C_{PBDG} = [3.42 m_{H_2,3} + 0.21 m_{CO_2,3} + 0.55 m_{CH_4,3} + 0.25 m_{CO,3} + 0.22 m_{O_2} + 0.299 m_{N_2}] / m_{BDG}$$

where:

T_6 = Mixed temperature of gases entering, compressor, F

$m_{H_2O, iv}$ = Mass flow of vapor entering system, pph

$m_{H_2O, ie}$ = Mass flow of entrained liquid entering system, pph

C_{PBDG} = Specific heat of dry gas exiting condenser, Btu/lbm-F

The energy required to raise the pressure of the recycle flow gases across the compressor is given by:

$$Q_c = \frac{m_r R (T_G + 460) \gamma_4 \left[\left(\frac{P_r}{P_{cond}} \right)^{\frac{\gamma_4-1}{\gamma_4}} - 1 \right]}{778 MW_4 (\gamma_4-1) \eta_a}$$

where: R = Universal gas constant = 1545 ft-lbf/mole-R

P_r = Reactor pressure = 24.3 psia

η_a = Aerodynamic efficiency of compressor = 1.0

Q_c = Compressor energy into recycle gas, Btu/hr

The total power consumed by the compressor is given by:

$$W_c = \frac{Q_c}{\epsilon_c 3.41}$$

where: W_c = Power to run compressor, watts

ϵ_c = Motor efficiency of compressor

Therefore, the heat lost to the ambient is:

$$Q_a = 3.41 W_c - Q_c$$

The heat of reaction in the reactor is:

$$Q_r = 973 \times m_{CO_2,i}$$

Essentially, it is assumed that the input gases are stoichiometric in ratio which then causes the mole fractions of the gases to remain constant in the recycle loop. The temperature out of the compressor is:

$$T_4 = T_6 + \frac{Q_c}{m_r C_{p4}}$$

The temperature out of the reactor is:

$$T_1 = T_r - \frac{Q_{LR}}{m_r C_{p4}}$$

where: Q_{LR} = Heat loss from reactor = 0.0 Btu/hr

The temperature into the condenser is:

$$T_2 = T_1 - \epsilon_{HX} (T_1 - T_4)$$

where: ϵ_{HX} = Heat exchanger efficiency = 0.85

Finally, the temperature of the gases leaving the condenser is:

$$T_3 = T_2 - \epsilon_c (T_2 - T_{cool})$$

where: ϵ_c = Condenser efficiency = 0.90

This T_3 is compared with the original gressed T_3 . If they agree within 0.3 F, the iteration is complete; otherwise, this T_3 is tried as the next gress.

C.3.3 Static Feed Water Vapor Electrolysis (KOH)

The Static Feed Water Vapor Electrolysis subsystem uses KOH as the medium for electrolysis to produce oxygen. This model is based on the ELCELL subroutine in G189A [2]. The following assumptions are used:

- (1) The unit is isothermal within the cells.

- (2) Product gas streams exit at the prevailing cell temperature.
- (3) The cell Faradaic efficiency is 100%; the cells are voltage inefficient only.
- (4) All cells are connected in series, i.e., the same input current passes through each cell.
- (5) The thermoneutral voltage is 1.48 volts; the voltage efficiency is equal to the thermoneutral voltage divided by the actual voltage.

The gas production is calculated as follows:

$$J = I/A$$

$$m_{H_2O,e} = N_c I/1350$$

$$m_{H_2,p} = m_{H_2O,e} / MW_{H_2O}$$

$$n_{O_2,p} = n_{H_2,p}/2$$

where: I = Input current to cells, amps
 A = Area of one cell, ft^2
 N_c = Number of cells
 $m_{\text{H}_2\text{O}, e}$ = Mass flow of O_2 consumed by electrolysis lbm/hr
 J = Cell current density, amps/ ft^2
 $n_{\text{H}_2, p}$ = Molar flow of hydrogen produced, moles/hr
 $n_{\text{O}_2, p}$ = Molar flow of oxygen produced, moles/hr

The details of the analytical method are described fully in the G189A manual for the subroutine ELCELL. However, the calculation of the energy required for electrolysis is computed according to the following equations and tables:

First, the cell voltage at 150 amps/sq. ft. current density for any cell temperature is determined by interpolation of the following table:

T_c ($^{\circ}\text{F}$)	V_o (Volts)
110	1.660
120	1.620
130	1.575
140	1.550
150	1.530
160	1.500
170	1.475
180	1.465
190	1.450

For cell temperatures less than 110 F, the voltage is set to 1.70 volts.

Next, the effect of a current density different from 150 amps/sq. ft. is found by interpolating the following table:

<u>J</u> <u>(amps/ft)</u>	<u>Delta V/Delta J</u> <u>(Volts/ASF)</u>
0	0.01460
100	0.00060
200	0.00055
300	0.00050
400	0.00050
500	0.00045
600	0.00045

Then the following is used to calculate the cell voltage:

$$V_c = V_0 + \frac{V}{J} (J-150)$$

The cell efficiency is:

$$\eta = \frac{1.48}{V_c} 100$$

and is limited to a peak value of 99%.

Lastly, the energy required for electrolysis is given by:

$$Q = N_c I V_c 3.413$$

C.3.4 Plate Fin Condensing Heat Exchanger

This subroutine models the performance for a plate fin condensing heat exchanger. Basically, the program iterates on the condenser



C.3.4 Plate Fin Condensing Heat Exchanger (Continued)

outlet temperature until the outlet temperature does not change from iteration to iteration.

First, the inlet dew point is calculated:

$$\omega_i = \frac{m_{v,i}}{m_{o,i}}$$

$$P_{v,i} = \frac{\omega_i P_{t,i}}{\omega_i + 0.622}$$

$$T_{dp,i} = T_{sat}(P_{v,i})$$

where: $m_{v,i}$ = Mass flow of inlet vapor, pph

$m_{da,i}$ = Mass flow of dry air, pph

ω_i = Inlet absolute humidity

$P_{t,i}$ = Inlet air total pressure, psia

P_{vi} = Inlet air partial pressure of water, psia

The initial guess at the exit temperature is one quarter of the way from the coolant inlet temperature to the air inlet temperature:

$$T_{a,e} = T_{c,i} + 1/4 (T_{c,i} + T_{a,i})$$

From the exit temperature, the outlet absolute humidity and vapor pressure are calculated:

$$P_{v,e} = P_{\text{sat}} (T_{a,e})$$

$$\omega_e = 0.622 \frac{P_{v,e}}{P_T - P_{v,e}}$$

The heat loads are then:

$$Q_L = M_{da,i} (\omega_i - \omega_e) h_{fg}$$

$$Q_s = m_{a,i} C_{p,a} (T_{a,i} - T_{a,e})$$

$$Q_t = Q_s + Q_L$$

where: h_{fg} = Heat of vaporization, Btu/lbm

Q_L = Latent heat, Btu/hr

Q_s = Sensible heat, Btu/hr

Q_t = Total heat loss, Btu/hr

$m_{a,i}$ = Total mass flow of air into Hx, lbm/hr

The coolant exit temperature is:

$$T_{c,e} = T_{c,i} + \frac{Q_t}{m_c C_{p,c}}$$

where: m_c = Coolant flow, pph

$C_{p,c}$ = Specific heat of water, Btu/lbm-F

From here, various properties of the air and coolant are calculated as a function of the average temperature. The properties and nondimensional numbers calculated are:

- μ = Viscosity
- K = Thermal conductivity
- P_r = Prandtl number
- R_e = Reynolds number
- C_{o1} = Colburn factor
- C_{mod} = Modified Colburn factor

The conditions are shown in the listing presented in the User's Manual [4]. Also shown there are various geometric dimensions such as fin height.

The film coefficient is chosen as the maximum of the following two equations:

$$h = 3.65 K/D_h$$

$$h = C_{mod} C_p G P_r^{-.6667}$$

Overall fin efficiency is then computed from the following fin equations:

$$m = \sqrt{\frac{2h}{KW}}$$

C-2

where: h = Film coefficient
 k = Thermal conductivity of fin
 W = Fin thickness
 L = Fin length

$$k = \frac{\tanh mL}{mL}$$

$$\eta = 1 - \frac{A_f (1-k)}{A}$$

where: A_f = Surface area of fins only, ft^2
 A = Total exposed surface area, including the fins and the unfinned primary surface, ft^2
 k = Fin effectiveness
 η = Total surface temperature effectiveness or overall fin efficiency

The effective UA becomes:

$$UA = \eta hA$$

The total effective dry UA is calculated as:

$$UA_{\text{dry}} = \frac{1}{\frac{1}{UA_c} + \frac{1}{UA_a}}$$

where: UA_c = Cold side effective UA, Btu/hr-F
 UA_a = Hot or air side effective UA, Btu/hr-F

The pinch point temperatures for the air side and coolant side are given by:

$$T_{pp,a} = \frac{\left(\frac{UA_a}{UA_c} T_{dp,i} + T_{dp,i} - T_{c,e} \right) C_{p,c} m_c + m_{a,i} C_{p,a} T_{a,i}}{m_{a,i} C_{p,a} + m_c C_{p,c} \frac{UA_a}{UA_c}}$$

The pinch point temperatures for the air and the coolant are those which occur at the location where the wall temperature equals the inlet dew point temperature:

$$T_{pp,c} = T_{dp,i} - \frac{UA_a}{UA_c} (T_{pp,a} - T_{dp,i})$$

These above equations can be derived from the simultaneous solution of the following two energy balances:

$$UA_a (T_{pp,a} - T_{dp,i}) = UA_c (T_{dp,i} - T_{pp,c})$$

$$m_{a,i} C_{p,a} (T_{pp,a} - T_{a,i}) = M_c C_{p,c} (T_{pp,c} - T_{c,e})$$

The wet side and dry side log mean temperature differences are:

$$T_{w,1m} = \frac{(T_{a,e} - T_{c,i}) - (T_{pp,a} - T_{pp,c})}{\ln \left(\frac{T_{a,e} - T_{c,i}}{T_{pp,a} - T_{pp,c}} \right)}$$

$$T_{d,1m} = \frac{(T_{pp,a} - T_{pp,c}) - (T_{a,i} - T_{c,e})}{\ln \left(\frac{T_{pp,a} - T_{pp,c}}{T_{a,i} - T_{c,e}} \right)}$$

Now, the wet and dry section dry UA's are:

$$UA_{d,ws} = \frac{m_c (T_{pp,c} - T_{c,i}) \frac{UA_c}{UA_h} + \frac{Q_t}{Q_s}}{\frac{Q_t}{Q_s} \frac{UA_c}{UA_h} + 1}$$

$$UA_{d,ds} = \frac{m_c (T_{c,e} - T_{pp,c})}{T_{d,1m}}$$

The total effective dry UA is:

$$UA_{d,tot} = UA_{d,ws} + UA_{d,ds}$$

The air exit temperature is iterated upon until:

$$UA_{d,tot} = UA_{dry}$$

C.3.5 Control

The control of the Space Station model is done in subroutine GPOLY1. The following paragraphs describe the control laws used to control:

- (a) Oxygen partial pressure
- (b) Total cabin pressure
- (c) Oxygen accumulator pressure
- (d) Temperature control
- (e) CO₂ accumulator exit flow control
- (f) H₂-CO₂ mix to CO₂ reduction unit

Oxygen partial pressure is controlled by using the same technique as described in the original ESCM Model Description Document [1]. The controller maintains oxygen partial pressure between 3.09 and 3.23 psia.

Total cabin pressure is maintained by the addition of nitrogen. The controller admits nitrogen to bring the pressure up to 14.813 psia only after the oxygen pressure is above 3.09 psia. The original Model Description Document [1] should be seen for more detail.

The oxygen accumulator pressure is maintained by addition of oxygen from the oxygen generators as oxygen is drawn from the accumulators to maintain cabin O₂ partial pressure. The current to the oxygen generators is regulated to each of the generators according to the following law:

$$\begin{array}{ll}\text{For } P_{O_2} \geq 1050 & I = 0.9 I_{nom} \\ \text{For } P_{O_2} \leq 950 & I = 1.1 I_{nom} \\ \text{For } 950 < P_{O_2} < 1050 & I = I_{nom}\end{array}$$

As the current is increased, the oxygen generation by the electrolysis unit increases.

For temperature control, the bypass flow around the condensing heat exchanger is regulated. A proportional plus integral scheme is used:

$$R = 0.05 E + \int 0.0001 E dt$$

where: R = Fraction of flow to bypass Hx.

$$E = \text{Temperature error} = T_{set} - T_{act}$$

As more flow bypasses the Hx, the mixed flow after the Hx is hotter.

Carbon dioxide removed from the air is sent to an accumulator. Each CO₂ removal unit has its own accumulator in a nonbussed system. The flow out of the accumulator is regulated to maintain pressure in the accumulator above 21 psia. Essentially, the average CO₂ removal rate during the past molecular sieve cycle is used as the flow out of the accumulator for the present cycle.

Lastly, the H₂-CO₂ mixture into the CO₂ Reduction unit is regulated to be stoichiometric by venting excess hydrogen after being produced by the oxygen generators. The required H₂ flow and the amount to be vented is given by:

$$m_{H_2} = 2 m_{CO_2} \frac{MW_{H_2}}{MW_{CO_2}}$$

$$R = m_i - \frac{m_i - m_{H_2}}{m_i}$$

where: m_{CO_2} = Flow of CO₂ to reduction, pph
 m_{H_2} = Stoichiometric flow of H₂ to reduction, pph
 m_i = Inlet flow to splitter, pph
 R = Fraction of H₂ inlet flow to be vented

ORIGINAL PAGE IS
OF POOR QUALITY
Report Documentation Page



1. Report No. NASA CR-181738		2. Government Accession No.		3. Recipient's Catalog No.	
4. Title and Subtitle Appendices to the Model Description Document for A Computer Program for the Emulation/Simulation of a Space Station Environmental Control and Life Support System				5. Report Date September 1988	
				6. Performing Organization Code	
7. Author(s) James L. Yanosy				8. Performing Organization Report No. SVHSER 10638	
				10. Work Unit No. 506-49-31-01	
9. Performing Organization Name and Address Hamilton Standard Division of United Technologies Corporation Windsor Locks, CT 06096				11. Contract or Grant No. NAS1-17397	
				13. Type of Report and Period Covered Contractor Report	
12. Sponsoring Agency Name and Address NASA Langley Research Center Hampton, VA 23665-5225				14. Sponsoring Agency Code	
15. Supplementary Notes Langley Technical Monitors: John B. Hall, Jr., and Lawrence F. Rowell					
16. Abstract A Model Description Document for the Emulation Simulation Computer Model was published previously. The model consisted of a detailed model (emulation) of a SAWD CO ₂ removal subsystem which operated with much less detailed (simulation) models of a cabin, crew, and condensing and sensible heat exchangers. The purpose was to explore the utility of such an emulation/simulation combination in the design, development, and test of a piece of ARS hardware - SAWD. Extensions to this original effort are presented in the manual. The first extension is an update of the model to reflect changes in the SAWD control logic which resulted from test. In addition, slight changes were also made to the SAWD model to permit restarting and to improve the iteration technique. The second extension is the development of simulation models for more pieces of air and water processing equipment. Models are presented for: EDC, Molecular Sieve, Bosch, Sabatier, a new condensing heat exchanger, SPE, SFWES, Catalytic Oxidizer, and multifiltration. The third extension is to create two system simulations using these models. The first system presented consists of one air and one water processing system. The second system consists of a potential Space Station air revitalization system complete with a habitat, laboratory, four modes, and two crews.					
17. Key Words (Suggested by Author(s)) Computer Simulation, Environmental Control, Space Station, Life Support, Computer Modeling				18. Distribution Statement Unclassified - Unlimited Subj. Cat. - 54	
19. Security Classif. (of this report) Unclassified		20. Security Classif. (of this page) Unclassified		21. No. of pages 96	
				22. Price A05	

PREPARATION OF THE REPORT DOCUMENTATION PAGE

The last page of a report facing the third cover is the Report Documentation Page, RDP. Information presented on this page is used in announcing and cataloging reports as well as preparing the cover and title page. Thus it is important that the information be correct. Instructions for filling in each block of the form are as follows:

Block 1. Report No. NASA report series number, if preassigned.

Block 2. Government Accession No. Leave blank.

Block 3. Recipient's Catalog No. Reserved for use by each report recipient.

Block 4. Title and Subtitle. Typed in caps and lower case with dash or period separating subtitle from title.

Block 5. Report Date. Approximate month and year the report will be published.

Block 6. Performing Organization Code. Leave blank.

Block 7. Author(s). Provide full names exactly as they are to appear on the title page. If applicable, the word editor should follow a name.

Block 8. Performing Organization Report No. NASA installation report control number and, if desired, the non-NASA performing organization report control number.

Block 9. Performing Organization Name and Address. Provide affiliation (NASA program office, NASA installation, or contractor name) of authors.

Block 10. Work Unit No. Provide Research and Technology Objectives and Plans (RTOP) number.

Block 11. Contract or Grant No. Provide when applicable.

Block 12. Sponsoring Agency Name and Address. National Aeronautics and Space Administration, Washington, D.C. 20546-0001. If contractor report, add NASA installation or HQ program office.

Block 13. Type of Report and Period Covered. NASA formal report series; for Contractor Report also list type (interim, final) and period covered when applicable.

Block 14. Sponsoring Agency Code. Leave blank.

Block 15. Supplementary Notes. Information not included elsewhere: affiliation of authors if additional space is re-

quired for block 9, notice of work sponsored by another agency, monitor of contract, information about supplements (film, data tapes, etc.), meeting site and date for presented papers, journal to which an article has been submitted, note of a report made from a thesis, appendix by author other than shown in block 7.

Block 16. Abstract. The abstract should be informative rather than descriptive and should state the objectives of the investigation, the methods employed (e.g., simulation, experiment, or remote sensing), the results obtained, and the conclusions reached.

Block 17. Key Words. Identifying words or phrases to be used in cataloging the report.

Block 18. Distribution Statement. Indicate whether report is available to public or not. If not to be controlled, use "Unclassified-Unlimited." If controlled availability is required, list the category approved on the Document Availability Authorization Form (see NHB 2200.2, Form FF427). Also specify subject category (see "Table of Contents" in a current issue of STAR), in which report is to be distributed.

Block 19. Security Classification (of this report). Self-explanatory.

Block 20. Security Classification (of this page). Self-explanatory.

Block 21. No. of Pages. Count front matter pages beginning with iii, text pages including internal blank pages, and the RDP, but not the title page or the back of the title page.

Block 22. Price Code. If block 18 shows "Unclassified-Unlimited," provide the NTIS price code (see "NTIS Price Schedules" in a current issue of STAR) and at the bottom of the form add either "For sale by the National Technical Information Service, Springfield, VA 22161-2171" or "For sale by the Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402-0001," whichever is appropriate.